

96-D Allen Boulevard Farmingdale, New York 11735-5626 USA Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956 e-mail: testing@govmark.com

Page 1

3-06220-0-Received: 01/26/2015 | Completed: 01/29/2015 | Letter: H JS P.O.#: Test Report #: Client's

Identification

Style: 9800/Parquet. Content: 100% Polyester F.R.. Width: 72". End Use: Cubicle, Drapery, Bedspread.

Tested For: John Hearn Interspec

**PO Box 705** 

Allenwood, NJ 08720

Key Test: NFPA 701-2010 TM#1

205

Tel: 1-(732)-938-4114

Ext:

Fax: 1-(732)-938-9083

PC: 0.5H

DL/jd

TEST PERFORMED: NFPA 701 - Standard Methods of Fire Tests for Flame Propagation of Textiles and Films

- 2010 Edition - Test Method #1

PRODUCT CONFIGURATION: [x] Single Layer; [ ] Multi Layer

RESULTS REPORTED: [x] Initially; [ ] After 3 dry cleanings; [ ] After 5 launderings @ 160°F

RESULTS:

	Afterflame*	Flaming Drip	Weight Loss
Specimen #	(seconds)	(seconds)	(percent)
1	1.4	0	6.3
2	0.0	0	22.6
3	0.0	0	36.5
4	0.0	0	1.7
5	0.0	0	29.0
6	0.0	0	3.2
7	0.0	0	8.3
8	0.0	0	27.4
9	0.0	0	5.0
10	0.0	0	19.0

15.9 Mean:

STATISTICAL VALUES: SD = 12.5 3 SD = 37.6 Mean + 3 SD = 53.5

ABBREVIATIONS USED: SD = Standard deviation. NT = Not tested.

APPROXIMATE WEIGHT OF MATERIAL (as measured by Govmark):  $201 \text{ g/m}^2$ 

PRECONDITIONING: [x] 0.5 hr @ 220°F (Standard)

[ ] 24 hrs @ 68±9°F (Alternate: Material shrinks/distorts @ 220°F)

CONVERSION FACTOR:  $g/m^2 \div 28.35 \times .835 = oz/yd^2$ 

## NOTE:

- 1. All specimens prepared in the length direction.
- 2. See addendum for individual specimen weights.

(Page 1 of 3)



96-D Allen Boulevard Farmingdale, New York 11735-5626 USA Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956 e-mail: testing@govmark.com

Page 2

Received:01/26/2015	Completed: 01/29/2015 Lette	r: H JS	P.O.#:	Test Report #:	3-06220-0-		
Client's Style: 9800/Parquet. Content: 100% Polyester F.R Width: 72". End Use: Cubicle, Drapery, Bedspread.  Identification							
Tested For: John He	arn		Key Test:	NFPA 701-2010 TM#1	205		
Interspec	0.5		T.I.	1 (722) 029 4114 E			
PO Box 705 Allenwood, NJ 08720				1-(732)-938-4114 Ext: 1-(732)-938-9083			
			A CONTRACTOR OF THE CONTRACTOR				
REMARKS:							
	not project above the jected above the top o						
FAILURE CRITERIA:	As cited by NFPA 701	- 2010 Editi	on Test Method #1				
	Flaming Drip	Weight Loss	(percent)				
Afterflame	(Mean)		Individual S	*			
*	Exceeds 2 seconds						
CONCLUSION: Based on the Results on page 1 and the above Failure Criteria cited by NFPA 701 - 2010 Edition Test Method #1, the item tested:  [x] Passes; [] Fails; [] Requires testing of 10 additional specimens							
AUTHORIZED SIGNAT GOVMARK /pm /gb		S. PHYLLIS					



96-D Allen Boulevard Farmingdale, New York 11735-5626 USA Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956 e-mail: testing@govmark.com

Page 3

Received: 01/26/2015 | Completed: 01/29/2015 | Letter: H JS P.O.#: Test Report #: 3-06220-0-

Identification

Client's

Style: 9800/Parquet. Content: 100% Polyester F.R.. Width: 72". End Use: Cubicle, Drapery, Bedspread.

Tested For: John Hearn

Interspec

**PO Box 705** 

Allenwood, NJ 08720

Key Test: NFPA 701-2010 TM#1

205

**Tel:** 1-(732)-938-4114 Fax: 1-(732)-938-9083

Ext:

## \*\* DISCUSSION:

Weight Loss - Individual Specimen Failure: ------

The NFPA 701 document, as written, provides for a statistical calculation which provides for retest and a potential failure if any individual value exceeds the mean by three standard deviations. Govmark is of the opinion that this cannot mathematically occur, i.e. no individual result is mathematically capable of exceeding the mean plus three standard deviations. Therefore, in effect, Govmark is of the opinion that this "individual specimen criteria" has no meaning, since it cannot possibly result in a nonconformance.

(Page 3 of 3)



96D Allen Blvd. Farmingdale, NY 11735 TEL: (516) 293-8944

FAX: (516) 293-8956

Client Name

: INTERSPEC

Addendum to Test Report # : 3-06220-0-H

Test:

: NFPA 701

Specimen #	Weight Before Test (g)	Weight After Test (g)	Percent Weight Loss
1	12.60	11.80	6.3
2	12.40	9.60	22.6
3	12.60	8.00	36.5
4	12.00	11.80	1.7
5	12.40	8.80	29.0
6	12.40	12.00	3.2
7	12.00	11.00	8.3
8	12.40	9.00	27.4
9	12.00	11.40	5.0
10	12.60	10.20	19.0

Mean Percent Weight Loss : 15.9 : 12.5 Standard Deviation

: 37.6 3 x Standard Deviation

Mean + 3 x Standard Deviation : 53.5